

Driveway Design Requirements

1. Driveways shall be at least fifteen (15) feet wide and may be no longer than one thousand (1,000) feet.
2. All gravel driveways that provide access to active areas of construction must be completed and capable of bearing emergency vehicle loads before construction activities may commence. All paved driveways that provide access to active areas of construction must have the first course of bituminous or concrete material completed and capable of bearing emergency vehicle loads before construction activities may commence.
3. Minimum driveway cross-sections are included on the “Driveway Cross Sections” page. (see web-site)
4. Parking lot pavement sections shall be designed to accommodate the types of traffic anticipated.